



LDAR Facility Agency DOR Summary

Report run at: 5/16/2024

Unit Type: Process Unit

StartDate: 2/8/2024

EndDate: 5/16/2024

Units: All Units

Unit	Regulation	Tag	Type	Location Description	DOR Approver	DOR Why	DOR Comment	Initial LeakDate	Date Opened	EstRepair Date	Date Closed	DOR CloseWhy
Crude												
HON		3452345	VALVE	0\4 75T003 DEPROP TWR 2FT W OF Pump 245	Mr. Anderson	IsoHAP/VOC		10/10/22	10/17/22	6/31/2024		
HON		21233	COMPRESSOR	0\2 Tower 3 2FT N OF 85D1	Mr. Anderson	Technically Infeasible without a process unit shutdown		9/16/22	9/27/22	5/31/24		
HON		565645	VALVE	1\2 N OF PUMP 84	Mr. Anderson	Technically Infeasible without a process unit shutdown		12/2/22	12/20/22	3/31/25		
HON		23123	VALVE	1\2 N OF COMPRESSOR 56	Mr. Anderson	Technically Infeasible without a process unit shutdown		10/13/21	10/26/21	3/31/25		
HON		56865	VALVE	1\1 N OF 75D-004 ON SESD	Mr. Anderson	Technically Infeasible without a process unit shutdown	Cannot be isolated unless unit is down.	1/5/22	1/18/22	3/31/25		

Total: 5