



Full Data Leak History

StartDate: 12/01/2023

EndDate: 2/08/2024

Unit Type: Location Unit

Regulations: Reg-A, Reg-B

Units: Unit 1

Comp Types: VALVE

Unit: UNIT 1	SIZE: 3.00 0	LOCATION: SITE 1	PROFILE: Active	DOR STATUS:
Tag: 1	AREA:	STREAM: STREAM 1	TUWHY:	DOR AUTH BY:
Type: VALVE, V-GATE,	SUBAREA:	ISOLATABLE: No	NEXT ACT: ReTest	EST REP DATE:
PHYS State: LL		CVS: No	DTM HOW:	

M21 Leaks

LeakDate	Leak Def	Regs	LkPpm	Bkgd	EmPt	1stAtt Done	1stReT Done	FinalRes Done	CloseDate	CloseWhy
01/01/24	500	Reg-A, Reg-B	1667	0	Packing	DateDue 01/05/24	01/05/24	01/10/24	01/20/24	Pass
						Status 01/02/24	01/02/24	01/15/24		

Att Date	AttType	AttMethod	AttBy	AttComment	InspDate	Insp Why	Tech	PPM	Analyzer	AVO Result	AVOType	InspComment
					1/1/2024	mmQ	Mary Fixit	1667	phx42-xxxx			
1/2/2024	Simple	Tighten	Bob Fixer								Simple	
					1/1/2024	Retest	Mary Fixit	1314	phx42-xxxx			
1/2/2024	Simple	Tighten	Bob Fixer								Simple	
1/2/2024	Simple	Tighten	Bob Fixer								Simple	
					1/1/2024	Retest	Mary Fixit	371	phx42-xxxx			